



Grid Emergency Report

To: GEN NZ Participants
Sent: 13-apr-2011 07:40
Ref: 516667417

From: The System Operator
Telephone: 0800 488 500
Facsimile: 07 843 7176

Revision of:
Grid Emergency Notice ref:

Cause:	Unplanned outage Grid Zone 12
At:	Greymouth, Kumara / Dilmans, Hokitika, Otira
Starting:	12-apr-2011 09:22
Ending:	12-apr-2011 09:50
Action Taken:	A grid emergency was declared for restoration of supply to Greymouth, Kumara, Hokitika and Otira following an unplanned outage of Atarau Reefton Inangahua circuit 1.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.