



Grid Emergency Report

To: GEN NZ Participants

Sent: 16-aug-2011 21:44

Ref: 613558343

From: The System Operator

Telephone: 0800 488 500

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 613522492

Cause:	Insufficient transmission capacity Kinleith
At:	Kinleith
Starting:	16-aug-2011 18:38
Ending:	16-aug-2011 21:30
Action Taken:	Insufficient transmission capacity at Arapuni and Kinleith, also insufficient generation offers North of Kinleith, resulted in violations on Kinleith - Tarukenga 1 for a tripping of Hamilton - Whakamaru 1. The grid was reconfigured with a system split at Kinleith on circuit breaker 348.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.