



Grid Emergency Report

To: GEN NZ Participants
Sent: 13-nov-2011 08:09
Ref: 679815258

From: The System Operator
Telephone: 0800 488 500
Facsimile: 07 843 7176

Revision of:
Grid Emergency Notice ref:

Cause:	Voltage Limit exceeded Te Kowhai
At:	Te Kowhai
Starting:	13-nov-2011 00:42
Ending:	13-nov-2011 08:00
Action Taken:	Grid emergency declared for grid reconfiguration to remove Taumarunui-Te Kowhai circuit due to high post-contingent (loss of Huntly-Te Kowhai) volts on Te Kowhai 220kV.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.