



Grid Emergency Report

To: GEN NI Participants

Sent: 14-dec-2011 06:07

Ref: 703416901

From: The System Operator

Telephone: 0800 488 500

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 703212094

Cause:	Insufficient Reserve offers North Island
At:	North Island
Starting:	14-dec-2011 01:30
Ending:	14-dec-2011 05:00
Action Taken:	Increased reserve offers requested and risk plant constrained to resolve infeasibilities.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.