



Grid Emergency Report

To: GEN SI Participants
Sent: 15-dec-2011 20:09
Ref: 704653951

From: The System Operator
Telephone: 0800 488 500
Facsimile: 07 843 7176

Revision of:
Grid Emergency Notice ref: 704650914

Cause:	Insufficient transmission capacity Top of South Island
At:	Stoke
Starting:	15-dec-2011 15:51
Ending:	15-dec-2011 20:00
Action Taken:	<p>A Grid Emergency was declared for grid reconfiguration at Stoke due to the risk of a landslide in close proximity to Kikiwa - Stoke circuit 1 and Kikiwa - Stoke circuit 2.</p> <p>Stoke T7 High Voltage Circuit Breaker 722 was opened, and additional transmission capacity was offered.</p>

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.