



Grid Emergency Report

To: GEN NI Participants

Sent: 20-dec-2011 16:24

Ref: 708167353

From: The System Operator

Telephone: 0800 488 500

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 708087501

Cause:	Insufficient transmission capacity Arapuni, Lichfield, Kinleith
At:	Arapuni, Lichfield, Kinleith
Starting:	20-dec-2011 13:00
Ending:	20-dec-2011 16:00
Action Taken:	Due to insufficient generation at Arapuni and Kinleith the systems split was moved from Arapuni to Kinleith.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.