



TRANSPOWER

Grid Emergency Report

To: GEN NZ Participants
Sent: 20-feb-2017 16:07
Ref: 2337967697

From: The system operator
Telephone: 0800 488 500
Email: NMDData@transpower.co.nz

Revision of:
Grid Emergency Notice ref:

Cause:	Unplanned outage Balclutha, Berwick, Brydone, Edendale, Gore
At:	Balclutha, Berwick, Brydone, Edendale, Gore
Starting:	20-feb-2017 09:49
Ending:	20-feb-2017 11:04
Action Taken:	<p>Due to unplanned outages of the Balclutha - Berwick 1 and Berwick - Halfway Bush 1 circuits, a contingency of the Gore - Roxburgh circuit would overload Edendale - Invercargill circuit.</p> <p>Controllable load at Balclutha, Berwick, Brydone, Edendale and Gore was removed until generation at Berwick was connected and a system split on Brydone - Gore circuit was implemented.</p>

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.