



TRANSPOWER

# Grid Emergency Report

**To:** GEN NZ Participants  
**Sent:** 09-may-2017 05:33  
**Ref:** 2416335007

**From:** The system operator  
**Telephone:** 0800 488 500  
**Email:** NMDData@transpower.co.nz

**Revision of:**  
**Grid Emergency Notice ref:**

<b>Cause:</b>	Voltage Limit exceeded Upper South Island
<b>At:</b>	Atarau, Robertson, Inangahua
<b>Starting:</b>	09-may-2017 01:47
<b>Ending:</b>	09-may-2017 05:30
<b>Action Taken:</b>	Reconfigure the grid by removing Dobson_Reefton_Inangahua Circuit 2 to manage post contingent voltage violations for a Kikiwa_T2 contingency.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

#### **Limitation Of Liability/Disclaimer**

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.