



TRANSPOWER

# Grid Emergency Report

**To:** GEN NZ Participants  
**Sent:** 08-aug-2017 23:43  
**Ref:** 2507400472

**From:** The system operator  
**Telephone:** 0800 488 500  
**Email:** NMData@transpower.co.nz

**Revision of:**  
**Grid Emergency Notice ref:** 2507350438

<b>Cause:</b>	Unplanned outage Atiamuri Whakamaru
<b>At:</b>	Arapuni, Bay of Plenty
<b>Starting:</b>	08-aug-2017 19:30
<b>Ending:</b>	08-aug-2017 22:30
<b>Action Taken:</b>	A tripping of Atiamuri Whakamaru circuit 1 required the System Operator to reconfigure the grid by closing Arapuni CB 48.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

#### **Limitation Of Liability/Disclaimer**

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.