



TRANSPower

Grid Emergency Notice

To: GEN NZ Participants
Sent: 08-nov-2017 05:06
Ref: 2594173003

From: The system operator
Telephone: 0800 488 500
Email: NMDData@transpower.co.nz

Revision of:

Cause: Unplanned outage South Island, Upper South Island
Region or GXP affected: Kikiwa, Argyle, Blenheim, Atarau, Dobson, Greymouth, Inangahua, Stoke, Murchison, Robertson, Reefton, Culverden
Starting: 08-nov-2017 02:52
Ending: 08-nov-2017 06:30
Multiple trippings on 220kV network north of Islington, 110kV network north of Kikiwa and 66kV network north of Kumara

Consequences on the power system:

System operator needs to manage load to effect restoration.
System operator needs to reconfigure the grid the effect restoration.

The system operator advises:

Grid reconfiguration will occur

At:

South Island, Top of South Island

Demand Allocations:

Total

Consequences if insufficient responses by participants:

This notice is issued in accordance with Technical Code B - Emergencies, Schedule 8.3, Part 8

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.