

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 30 July 2008 at 11:15 hours until 12:09 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement, a Grid Emergency was declared for the restoration of supply to Hororata, following the tripping of Coleridge Hororata 2 & 3 and Hororata Islington 1 & 2.