

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 24 June 2008 at 18:00 hours until 18:40 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement, a Grid Emergency was declared because for the loss of the Huntly Otahuhu 2 circuit, the Bombay Hamilton 2 circuit would exceed its advised rating (due to the concurrent unplanned outages of the Arapuni Bombay 1 circuit and Huntly Otahuhu 1 circuit). Demand management at Bombay and Meremere alleviated the problem.