

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 12 February 2008 at 07:44 hours until 09:16 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement, a Grid Emergency was declared because the post contingent rating of Bombay Hamilton circuits 1 or 2 was at risk of being exceeded for a contingency of the other circuit. Demand was managed to alleviate this.