

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 08 March 2008 at 12:07 hours until 12:49 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement, a Grid Emergency was declared because the steady state voltage at Pakuranga was below EGR limit during a scheduled outage. Demand was managed to alleviate this until the outage was recalled.