

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 5 June 2008 at 10:45 hours until 15:29 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement, a Grid Emergency was declared because for the loss of the Cobb – Upper Takaka circuit 1 the Stoke – Upper Takaka circuit 1 would exceed it's advised rating. Demand management at Motueka and Motupipi alleviated the problem.