

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 03 December at 16:56 hours until 03 December at 19:00 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Grid Emergency was declared, as the short-term post contingent rating of Kikiwa T1 was at risk of being exceeded for a contingency of Blenheim-Stoke 1. Load management by Networks Tasman & Marlborough Lines and generation re-offers by Trustpower at Cobb alleviated the contingency.