

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 04 December at 05:41 hours until 04 December at 08:00 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Grid Emergency was declared, due to a fire near the HVDC circuits causing an unacceptable risk to the HVDC. The HVDC maximum South transfer limit was lowered to 180MW. Fire near the HVDC circuits passed and the Grid Emergency was ended at 06:20.