

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 08 November 2005 from 07:51 hours until 08 November 2005 08:27 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Grid Emergency was declared, as the full load rating of the Motueka-Stoke circuit was being exceeded due to loss Cobb generation. Load management was required at Motueka & Motupipi.