

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 08 November at 09:21 hours until 08 November at 13:07 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Grid Emergency was declared, as the short-term post contingent rating of Stoke-Upper Takaka 1 was at risk of being exceeded for a contingency of Cobb-Upper Takaka 1. Load management at Motueka & Motupipi alleviated the contingency.