

To: Electricity Governance Board

From: Transpower as System Operator

---

A Level 1 Grid Emergency was declared on 10 October 2005 from 07:41 hours until 10:00 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Grid Emergency was declared due to Zone 3 security limit being exceeded or was at risk of being exceeded. Load management was required at Blenheim, Kikiwa, Murchison, Motueka, Motupipi, Stoke, Westport, and Robertson Street.