

To: Electricity Governance Board

From: Transpower as System Operator

---

A Level 1 Grid Emergency was declared on 17 May 2005 from 11:35 hours until 21:00 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Level 1 Grid Emergency was declared due to GOS Zone 9 security limit being exceeded or was at risk of being exceeded. Load management was required at Blenheim, Kikiwa, Murchison, Motueka, Motupipi, Stoke, Westport, and Robertson Street.