

To: Electricity Governance Board

From: Transpower as System Operator

---

A Level 1 Grid Emergency was declared on 26 April 2005 from 17:56 hours until 20:00 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Level 1 Grid Emergency was declared as the short term post contingent ratings of Mount Maunganui circuit were at risk of being exceeded for a contingency of Tauranga Tarukenga circuit. Load management was required at Mount Maunganui, Tauranga and Te Matai.