

To: Electricity Governance Board

From: Transpower as System Operator

---

A Level 1 Grid Emergency was declared on 07 June 2005 from 10:30 hours until 17:20 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Level 1 Grid Emergency was declared, due to a short fall of Generation offers for the Tauranga 33kV point of supply during a planned outage on Tauranga 110kV bus section 247-287.