

To: Electricity Governance Board

From: Transpower as System Operator

---

A Level 1 Grid Emergency was declared on 08 June 2005 from 10:14 hours until 10:36 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Level 1 Grid Emergency was declared to enable restoration of supply to Mataroa following the tripping of the Bunnythorpe – Mataroa and Mataroa - Ohakune circuits.