

To: Electricity Governance Board

From: Transpower as System Operator

---

A Level 1 Grid Emergency was declared on 08 May 2005 from 12:00 hours until 12:30 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Level 1 Grid Emergency was declared, due to a short fall of Generation offers in the Top of the South Island during a planned outage on Kikiwa T1. No load management was required.