

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 24 September 2005 from 11:39 hours until 12:39 hours pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement para 52, a Grid Emergency was declared, as the short-term post contingent rating of Coleridge Otira 1 was at risk of being exceeded for a contingency of Coleridge Otira 2 and Coleridge Otira 2 was at risk of being exceeded for a contingency of Coleridge Otira 1. Load reductions alleviated the contingency.