



Grid Emergency Report

To: GEN SI Participants
Sent: 03-may-2010 20:51
Ref: 242973404

From: The System Operator
Telephone: 0800 488 500
Facsimile: 07 843 7176

Revision of:
Grid Emergency Notice ref: 242913118

Cause:	Insufficient Reserve offers South Island
At:	South Island
Starting:	03-may-2010 18:12
Ending:	03-may-2010 20:00
Action Taken:	Due to the unplanned loss of some South Island generation, there was insufficient reserve offers in the south island to cover for a contingent event. An increase in reserve offers from participants alleviated this situation.

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.