



Grid Emergency Report

To: GEN NZ Participants

Sent: 06-sep-2010 20:22

Ref: 342675448

From: The System Operator

Telephone: 0800 488 500

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 342607014

Cause:	Insufficient Generation offers Upper North Island
At:	Upper North Island
Starting:	06-sep-2010 17:10
Ending:	06-sep-2010 20:00
Action Taken:	Grid re-configured at KIN, Reserves reduced and Discretion used to dispatch offered generation north of Whakamaru

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.