



Grid Emergency Report

To: GEN NZ Participants

Sent: 07-may-2010 16:00

Ref: 246175547

From: The System Operator

Telephone: 0800 488 500

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 246174732

Cause:	Independent Action taken by Asset Owner Bream Bay T2
At:	Bream Bay T2
Starting:	07-may-2010 15:51
Ending:	07-may-2010 15:51
Action Taken:	The Asset Owner took independent action to remove from service Bream Bay T2 due to multiple operations of the low tension circuit breaker.

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.