



Grid Emergency Report

To: GEN NZ Participants

Sent: 18-feb-2010 16:17

Ref: 181835467

From: The System Operator

Telephone: 0800 488 500

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 181680359

Cause:	Unplanned outage HVDC Pole 2, HVDC Pole 1
At:	North Island
Starting:	18-feb-2010 11:49
Ending:	18-feb-2010 16:00
Action Taken:	Participants responded with additional generation. No reserves were dispatched for the North Island. North Island load was reduced by 5%.

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.