



# Grid Emergency Report

**To:** GEN NZ Participants  
**Sent:** 18-sep-2010 02:15  
**Ref:** 351019949

**From:** The System Operator  
**Telephone:** 0800 488 500  
**Facsimile:** 07 843 7176

**Revision of:**  
**Grid Emergency Notice ref:**

<b>Cause:</b>	Unplanned outage Hokitika Otira 2, Kumara Otira 1
<b>At:</b>	Hokitika, Greymouth, Kumara / Dilmans
<b>Starting:</b>	18-sep-2010 00:33
<b>Ending:</b>	18-sep-2010 00:48
<b>Action Taken:</b>	Grid Emergency declared to manage restoration of load after unplanned outage of Hokitika Otira 1 and Kumara Otira 1 during concurrent unplanned outage of Dobson Greymouth 1

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

#### Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.