



Grid Emergency Report

To: GEN NZ Participants
Sent: 18-sep-2010 22:47
Ref: 351557992

From: The System Operator
Telephone: 0800 488 500
Facsimile: 07 843 7176

Revision of:
Grid Emergency Notice ref:

Cause:	Insufficient Gen offers & transmission capacity Upper North Island
At:	Arapuni
Starting:	18-sep-2010 08:56
Ending:	18-sep-2010 21:00
Action Taken:	Insufficient transmission capacity at Arapuni and insufficient generation offers north of Kinleith resulted in Arapuni Hamilton 1 & 2 and Arapuni Kinleith 1 violations. The grid was reconfigured with system splits put in place at Kinleith to alleviate

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.