



Grid Emergency Report

To: GEN NI Participants

Sent: 21-apr-2010 02:50

Ref: 232494489

From: The System Operator

Telephone: 0800 488 500

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 232081879

Cause:	Insufficient Generation offers North Island
At:	North Island
Starting:	20-apr-2010 16:00
Ending:	20-apr-2010 21:30
Action Taken:	HVDC Pole 1 started to alleviate the need for load control.

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.