



# Grid Emergency Report

**To:** GEN NZ Participants  
**Sent:** 24-sep-2010 02:21  
**Ref:** 355533661

**From:** The System Operator  
**Telephone:** 0800 488 500  
**Facsimile:** 07 843 7176

**Revision of:**  
**Grid Emergency Notice ref:**

<b>Cause:</b>	Insufficient generation and transmission capacity Upper North Island
<b>At:</b>	Kinleith Tarukenga 1, Kinleith Tarukenga 2
<b>Starting:</b>	23-sep-2010 07:47
<b>Ending:</b>	23-sep-2010 21:00
<b>Action Taken:</b>	Insufficient transmission capacity at Arapuni and Kinleith, and insufficient generation offers north of Kinleith resulted in violations on Kinleith - Tarukenga 1 for a tripping of Hamilton - Whakamuru 1. The grid was reconfigured with system splits put in place at Kinleith.

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

#### Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.