



# Grid Emergency Report

**To:** GEN NZ Participants  
**Sent:** 24-apr-2010 17:22  
**Ref:** 235451867

**From:** The System Operator  
**Telephone:** 0800 488 500  
**Facsimile:** 07 843 7176

**Revision of:**  
**Grid Emergency Notice ref:**

<b>Cause:</b>	Unplanned outage Balclutha Halfway Bush 1
<b>At:</b>	Southland
<b>Starting:</b>	24-apr-2010 12:51
<b>Ending:</b>	24-apr-2010 16:38
<b>Action Taken:</b>	Due to an unplanned outage of the Balclutha - Halfway Bush 1 circuit, tripping of the Gore - Roxburgh circuit would overload Edendale - Invercargill circuit.  System split implemented on Brydone - Gore circuit by opening Gore 92.

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

#### Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.