



Grid Emergency Report

To: GEN NI Participants

Sent: 27-oct-2010 14:04

Ref: 380986593

From: The System Operator

Telephone: 0800 488 500

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 380984296

Cause:	Insufficient generation and transmission capacity Upper North Island
At:	Kinleith Tarukenga 1, Kinleith Tarukenga 2
Starting:	27-oct-2010 07:15
Ending:	27-oct-2010 14:00
Action Taken:	Insufficient transmission capacity at Arapuni and Kinleith, also insufficient generation offers north of Kinleith, resulted in violations on Kinleith - Tarukenga 1 for a tripping of Hamilton - Whakamuru 1. The grid was reconfigured with system splits at Kinleith on the Kinleith-Tarukenga circuits 1 and 2. Reduced load at Kinleith following the tripping of Arapuni Kinleith circuits 1 and 2 has now alleviated this situation.

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.