



Grid Emergency Report

To: GEN NI Participants
Sent: 11-jan-2011 22:08
Ref: 441613105

From: The System Operator
Telephone: 0800 488 500
Facsimile: 07 843 7176

Revision of:
Grid Emergency Notice ref:

Cause: Insufficient transmission capacity Kinleith
At: Kinleith
Starting: 11-jan-2011 15:00
Ending: 11-jan-2011 21:00
Action Taken: The Kinleith system split had been in place for a different outage.

Following the return of this outage, insufficient transmission capacity at Arapuni and Kinleith, also insufficient generation offers north of Kinleith, would have resulted in violations on Kinleith - Tarukenga 1 for a tripping of Hamilton - Whakamuru 1.

The Kinleith remained reconfigured with a system split at Kinleith.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.