



Grid Emergency Report

To: GEN NZ Participants
Sent: 26-mar-2011 13:50
Ref: 501844549

From: The System Operator
Telephone: 0800 488 500
Facsimile: 07 843 7176

Revision of:
Grid Emergency Notice ref:

Cause:	Unplanned outage South Island
At:	Balclutha, Brydone, Edendale, Gore
Starting:	26-mar-2011 10:15
Ending:	26-mar-2011 12:31
Action Taken:	Due to an unplanned outage of the Balclutha_Halfway Bush circuit, contingency violations occurred for the loss of the Gore_Roxburgh circuit overloading Invercargill T1 and Edendale_Invercargill circuit. Load was managed at Balclutha, Brydone, Edendale and Gore to alleviate.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.