Compliance plan for Nova Energy Limited

Relevant information				
Non-compliance	Description			
Audit Ref: 2.1	TODD			
With: 10.6, 11.2, 15.2	Some inaccurate data was not corrected as soon as practicable.			
	Profile discrepancy on the day of met	Profile discrepancy on the day of meter change for upgrades and downgrades.		
	Inaccurate submission for ARC Innova	ations HHR meter	ing.	
	WISE			
	One ICP had an incorrect inactive stat	cus event date.		
	HNET			
From: 01-Mar-21	One ICP had an incorrect Profile code	of PV1 where no	generation was present.	
To: 31-Mar-22	Potential impact: Low			
	Actual impact: Low			
	Audit history: Multiple times			
	Controls: Strong			
	Breach risk rating: 1			
Audit risk rating	Rationale	for audit risk rati	ng	
Low	Controls are rated as strong as they a	re sufficient to m	itigate risk most of the time.	
	The audit risk rating is low as the overall volume of ICPs affected is low. Where statuses are incorrect, the reconciliation process ensures that all consumption is reported. Status inaccuracies can have a minor impact on ICP days submissions.			
Actions tak	en to resolve the issue	Completion date	Remedial action status	
TODD Response: Non-Compliance accepted.			Identified	
See sections listed below for further details specific to each area.				
Items 1, 2 and 3 See Sections 3.5, 3.8 and 3.9 In all instances data integrity reporting identified the discrepancies as expected. Due to resource constraints Nova's processes were not followed to make corrections once issues were identified by the data integrity reporting. All corrections have now been made				
Item 6 See section 6.1. • Recommendation has been accepted.				

	_
WISE Response:	
Non-Compliance accepted.	April 2022
	April 2022
One ICP had incorrect Inactive status event date recorded in the	
 Registry. See section 3.9 The ICP was identified as part of the existing reporting, 	
however due to human error the wrong date was used	
to update the Registry. See section 3.9	
This was corrected to reflect the correct Inactive dates	
on 27/04/2022	
HNET Response:	
Non-Compliance accepted.	
	March 2022
One ICP had the incorrect profile applied. See section 6.1	
 This was due to human error and was corrected in 	
March 2022.	
March 2022. Preventative actions taken to ensure no further issues will	Completion
	Completion date
Preventative actions taken to ensure no further issues will	date
Preventative actions taken to ensure no further issues will occur	
Preventative actions taken to ensure no further issues will occur TODD:	date
Preventative actions taken to ensure no further issues will occur TODD: Detailed outcomes are covered in the applicable sections of the	date
Preventative actions taken to ensure no further issues will occur TODD: Detailed outcomes are covered in the applicable sections of the audit document WISE:	date
Preventative actions taken to ensure no further issues will occur TODD: Detailed outcomes are covered in the applicable sections of the audit document WISE: WISE will continue to focus on accuracy of event dates and	date
Preventative actions taken to ensure no further issues will occur TODD: Detailed outcomes are covered in the applicable sections of the audit document WISE:	date
Preventative actions taken to ensure no further issues will occur TODD: Detailed outcomes are covered in the applicable sections of the audit document WISE: WISE will continue to focus on accuracy of event dates and complete and accurate information.	date
Preventative actions taken to ensure no further issues will occur TODD: Detailed outcomes are covered in the applicable sections of the audit document WISE: WISE will continue to focus on accuracy of event dates and complete and accurate information. HNET:	date
Preventative actions taken to ensure no further issues will occur TODD: Detailed outcomes are covered in the applicable sections of the audit document WISE: WISE will continue to focus on accuracy of event dates and complete and accurate information.	date

Electrical Connection of Point of Connection			
Non-compliance	Description		
Audit Ref: 2.11	TODD		
With: 10.33A	41 ICPs did not have full certification within five business days of reconnection.		
	WISE		
	ICP 100112843LCC6D's meter was not re-certified on unbridging.		
	HNET		
	Six ICPs did not have full certification within five business days of reconnection.		
	Potential impact: Low		
	Actual impact: Low		
	Audit history: Three times		

From: 01-Mar-21 To: 14-Jan-21	Controls: Strong Breach risk rating: 1
Audit risk rating	Rationale for audit risk rating
Low	The controls are recorded as strong. Processes are in place to identify metering certification issues and replace affected meters.
	The impact on settlement is recorded as minor because installations with expired or interim certification may be less accurate than certified metering installations.

interim certification may be less accurate than certified metering installations.		
Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted.		Identified
Nova continues to work with MEPs on deployment program(s), BAU field jobs, turn downs due to additional electrical work required and consumer contact challenges etc. These challenges are on-going across the industry		
WISE Response: Non-Compliance accepted.	April 2022	
One ICP did not have the metering certification updated on the Registry within timeframe after being unbridged. • Due to the site switching from WISE shortly after the unbridging this was not identified by WISE's processes. WISE has since followed up with the MEP who has now corrected the Registry as the site was recertified at the time of work being undertaken.		
HNET Response: Non-Compliance accepted.		
Six late certifications for reconnections		
HNET has updated their service request template to capture if there is uncertified metering and due date to ensure updates are made within 5 working days		
Preventative actions taken to ensure no further issues will occur	Completion date	
Non-compliance will continue to occur as certifications continue to expire TODD will continue to work with MEPs to improve and/or meet the code timeframes WIST & UNITY	On-going	
WISE & HNET:		

WISE & HNET will continue to work with MEPs to meet the code	
timeframes	

Changes to registry information				
Non-compliance	Description			
Audit Ref: 3.3	TODD, HNET and WISE	TODD, HNET and WISE		
With: 10 Schedule 11.1	Some registry information was not up	dated within five	business days of the event.	
	Potential impact: Low			
	Actual impact: Low			
From: 01-Mar-21	Audit history: Multiple times			
To: 28-Jan-22	Controls: Moderate			
	Breach risk rating: 4			
Audit risk rating	Rationale	for audit risk rati	ng	
Medium	The controls for the timeliness and ac moderate for TODD and have improve			
	HNET and WISE controls are also moderate. Errors are identified and corrected by both HNET and WISE as soon as possible however due to the manual nature of these processes human error cannot be eliminated.			
	The audit risk rating is medium. While the vast majority of updates to the registry occur within the required timeframe, submission type changes made more than seven months after the event date can result in distortion of the PR030 seasonal adjusted shape values which traders use to create historic estimates and apportion consumption between revision periods, because the last version of the files used by traders is published following revision seven based on the submission information provided at that time.			
Actions taken to resolve the issue Completion Re		Remedial action status		
TODD Response: Non-Compliance accepted		On-going	Identified	
discrepancies as e Due to resource or required followin identification produring the audit p	ata integrity reporting identified the expected. constraints, the corrective actions g Nova's robust exception cesses were not always completed			
WISE & HNET Response: Non-Compliance accepted.				
Some registry information was not updated within 5 business days of the event.				

 HNET & WISE display on-going commitment to timely status updates which is reflected in our compliance results. In instances where backdated corrections are made, we elect to provide complete and accurate information and acknowledge this creates contention with Clause 	
10 Schedule 11.1. Preventative actions taken to ensure no further issues will	Completion
occur	date
TODD: Nova has considered and redistributed internal workflows to improve resource availability to this area. Further, we anticipate that the impact to staff availability due to COVID-19, and an incremental easing of the recruitment market moving forward, will result in increased compliance.	On-going
HNET: HNET has updated the service request template to capture uncertified metering and due date to ensure updates are made within 5 working days	
WISE & HNET: On-going work with our industry stakeholders to improve compliance time frames. Where required, we elect to provide complete and accurate information over timeliness. Our focus	

Provision of information to the registry manager

and accurate information.

will continue to be on accuracy of event dates and complete

Non-compliance	Description
Audit Ref: 3.5	TODD
With: 9 of schedule 11.1	254 late updates to active status for new connections.
	Ten newly connected ICPs (of a sample of 35) had incorrect active status event dates. Nine were corrected during the audit and 0000050570HRF60 will be corrected from 11/8/21 to 7/8/21 once the required network and MEP events have been reversed on the registry.
	HNET
	Two late updates to active status for new connections.
From: 01-Mar-21	Potential impact: Low
To:31-Mar-21	Actual impact: Low
	Audit history: Twice
	Controls: Moderate
	Breach risk rating: 2

Audit risk rating	Rationale for audit risk rating		
Low	potentially incorrect active status date timely manner. The audit risk rating is or are in the process of being corrected. The late updates were caused by reso	The controls are rated as moderate. Validation reporting is in place to detect potentially incorrect active status dates, but these are not always resolved in a timely manner. The audit risk rating is low, the discrepancies have been corrected or are in the process of being corrected. The late updates were caused by resourcing, corrections or delays in receiving confirmation of the correct active status date, and/or waiting for other parties to	
Actions to	aken to resolve the issue	Completion date	Remedial action status

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted.	April 2022	Identified
254 late updates to active status on New Connections.		
 10 ICPS with incorrect first active date. 9 were corrected during audit. ICP 0000050570HRF60 has now been corrected on the Registry and is reflecting the correct date of 07/08/2021 Data integrity reporting identified the discrepancies as expected. Due to resource constraints, the corrective actions required following Nova's robust exception identification processes were not always completed during the audit period. All corrections have now been made. 		
HNET Response: Non-Compliance accepted. Two late updates to active status for New Connections • HNET updates the Registry as soon as paperwork is received from the MEP HNET will continue to work with MEPs to ensure that timeframes are achieved in accordance with the code.		
Preventative actions taken to ensure no further issues will occur	Completion date	
Nova is developing an improvement for New Connections to increase efficiency and decrease the reliance on manual updates. This will reduce the risk of human error and the dependency on staff resource. Delivery by Q4 2022 In the interim Nova has considered and redistributed internal workflows to improve resource availability to this area. Further, we anticipate that the impact to staff availability due to COVID-19, and an incremental easing of the recruitment market moving forward will result in increased compliance.	On-going	

HNET:	
On-going work with our industry stakeholders to improve compliance time frames	

ANZSIC codes			
Non-compliance	Description		
Audit Ref: 3.6 With: 9 (1(k) Schedule 11.1	TODD Five ICPs had incorrect ANZSIC codes applied. All have been corrected. HNET Two incorrect ANZSIC codes.		
	Potential impact: None		
From: 01-Mar-21	Actual impact: None		
To:31-Jan-22	Audit history: Twice		
10.31-3811-22	Controls: Strong		
	Breach risk rating: 1		
Audit risk rating	Rationale	for audit risk rati	ng
Low	Controls for TODD have increased to strong, now that validation reports have been expanded to include all ICPs. The exceptions occurred before the validation proces was updated. Controls for HNET are moderate because most ANZSIC codes are checked on switch in, and a small number of exceptions were identified overall. Because most of the ICPs are supplied by TODD, and their processes are well designed and followed the controls are assessed to be strong overall. The audit risk rating is low this has no direct impact on submission accuracy.		
Actions tak	en to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted. Five ICPs had incorrect ANZSIC codes applied. • All have been corrected during audit		April 2022	Cleared
HNET Response: Non-Compliance accepted			
Two ICPs had incorrect ANZSIC codes applied.All have been corrected during audit			

Preventative actions taken to ensure no further issues will occur		Completion date
TODD:	Existing reporting was expanded to include all ICPs, rather than only new to Nova ICPS's, to find inaccuracies with ANZSIC records on 16 March 2021 New reporting was created focusing on new Commercial sites to confirm the ANZSIC code against the business record on the Companies register implemented 4 May 2021	May 2021
HNET: •	A six-monthly internal audit sample review across all ANZSIC codes has been instigated, with the first occurring May 2022. ANZSIC codes on all switch in sites will be confirmed at time of switch.	May 2022

Changes to unmetered load			
Non-compliance	Description		
Audit Ref: 3.7	TODD		
With: 9(1)(f) of Schedule 11.1	ICP 0000394464MP147 had an unmetered builder's temporary supply from 16/7/21 until a meter was installed on 23/11/21. No unmetered load was recorded on the registry or in Orion for the period with unmetered load.		
	ICP 0007198101RN234 had an unmetered BTS recorded and was confirmed to have been metered since it became active in 2020. A backdated removal of unmetered load was completed during the audit.		
	ICP 0007200589RNF1B had an unmetered BTS recorded, and it was confirmed that the connection should be made permanent in December 2021. No job has been raised to install metering to date. ICPs 0000020042CP198 and 0000020056CPA3F had their shared unmetered load removed by the distributor effective from 1/12/21. The registry and Orion's unmetered load flag, trader details and daily unmetered kWh have not been updated, and unmetered load submissions are continuing.		
From: 05-Nov-20	Potential impact: Low		
To: 21-Apr-22	Actual impact: Low		
	Audit history: None		
	Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale for audit risk rating		
Low	Monitoring controls are well designed and identify new unmetered load and unmetered load discrepancies daily, but the exceptions identified are not consistently investigated and resolved promptly due to resourcing.		

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted. • 0000394464MP147 had unrecorded UML for the period 16/7/2021 to 23/11/2021 when the permanent metering was installed. The site has now switched to another retailer and therefore this cannot be corrected. • 0007198101RN234 had the backdated removal of UML processed during the audit • 0007200589RNF1B is pending decommission as a new ICP was generated for the permanent metering.	May 2022	Identified
Two ICPs should have had shared UML removed from the registry in December 2021. See Section 5.1		
Preventative actions taken to ensure no further issues will occur	Completion date	
Nova accepts the recommendation from the auditor to clarify responsibilities within the operational teams for UML. Refresher training on the existing controls will be delivered by Q3 2022, and monthly compliance refresher sessions will commence with the Metering team in May 2022	On-going	
This area has been impacted by the resource constraints caused by COVID-19 with increased unplanned leave and experienced, knowledgeable team members leaving the business. Nova expects to see a return to our historical compliance achievement in the coming months.		

Management of "active" status			
Non-compliance	Description		
Audit Ref: 3.8	TODD		
With: 17 Schedule 11.1	10 newly connected ICPs of a sample of 35 had incorrect active status event dates. Nine were corrected during the audit and 0000050570HRF60 will be corrected from 11/8/21 to 7/8/21 once the required network and MEP events have been reversed on the registry.		
	Potential impact: Low		
From: 04-Feb-20	Actual impact: Low		
To: 05-Oct-20	Audit history: Multiple times		
	Controls: Moderate		
	Breach risk rating: 2		

Audit risk rating	Rationale for audit risk rating			
Low	The controls are rated as moderate, validation reporting is in place to detect potentially incorrect active status dates, but these are not always resolved in a timely manner. The audit risk rating is low, the discrepancies have been corrected or are in the process of being corrected.			

or are in the process of being corrected.			
Actions taken to resolve the issue	Completion date	Remedial action status	
TODD Response: Non-Compliance accepted.	April 2022	Identified	
 10 ICPs with incorrect first active date. See Section 3.5 Data integrity reporting identified the discrepancies as expected. Due to resource constraints, the corrective actions required following Nova's robust exception identification processes were not always completed during the audit period. All corrections have now been made. ICP 0000050570HRF60 has now been corrected on the Registry and is reflecting the correct date of 07/08/2021 			
Preventative actions taken to ensure no further issues will occur	Completion date		
Nova is developing an improvement for New Connections to increase efficiency and decrease the reliance on manual updates. This will reduce the risk of human error and the dependency on staff resource. Delivery by Q4 2022 In the interim Nova has considered and redistributed internal workflows to improve resource availability to this area. Further, we anticipate that the impact to staff availability due to COVID-19, and an incremental easing of the recruitment market moving forward will result in increased compliance.	On-going		

Management of "inactive" status			
Non-compliance	Description		
Audit Ref: 3.9	TODD		
With: 19 Schedule 11.1	Eight ICPs were recorded with 1,11 "electrically disconnected at meter box switch" which should have had the status 1,12 "new connection in progress". One was corrected during the audit, but ICPs 0007200708RNC13, 0000165673CK414, 0007201054RN9A7, 1000028279BP1F9, 1002137708LC9F9, 0007201721RNEB7 and 0007201721RNEB7 still have incorrect status reasons recorded for historic status records.		
From: 26-Mar-21 To: 04-Jun-21	Incorrect active event dates for ICPs 0008762650CN572 and 0000081478TR1F3. WISE		

	One ICP had an incorrect inactive status event date.		
	Potential impact: Low		
	Actual impact: None		
	Audit history: Twice		
	Controls: Strong		
	Breach risk rating: 1		
Audit viels veting	Rationale for audit risk rating		
Audit risk rating	Kationale for audit risk rating		
Low	The controls are assessed to be strong overall. • The incorrect status reason codes for TODD occurred due to a training issue and the incorrect records were created by one user ID. The issue did not recur after June 2021.		
-	The controls are assessed to be strong overall. • The incorrect status reason codes for TODD occurred due to a training issue and the incorrect records were created by one user ID. The issue did		
-	The controls are assessed to be strong overall. • The incorrect status reason codes for TODD occurred due to a training issue and the incorrect records were created by one user ID. The issue did		

not. There is no impact on volume or ICP days submissions.

For WISE one ICP had an incorrect inactive status event date as this event was not amended once it was identified that the disconnection was

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response:	April 2022	Cleared
Non-Compliance accepted.	7,0111 2022	Cicarca
Eight ICPs recorded as 1,11 instead of 1,12		
One corrected in audit		
 Two corrected shortly after audit 		
 Five switched to another retailer before the correction could be made 		
Two ICPs with incorrect active event dates		
 One has been corrected 		
 One is still under investigation to confirm dates as this was caused by a house fire with conflicting information provided 		
WISE Response:		
Non-Compliance accepted.		
One ICP had incorrect Inactive status event date recorded in the		
Registry		
 The ICP was identified as part of the existing reporting, however due to human error the wrong date was used to update the Registry. 		
This was corrected to reflect the correct Inactive dates on		
27/04/2022		

unsuccessful.

Preventative actions taken to ensure no further issues will occur	Completion date
 Our focus will continue to be on accuracy of event dates and complete and accurate information. Nova will monitor disconnected ICPs on an on-going basis and where required, look for opportunities for improvements. 	On-going
WISE:	
WISE will continue to focus on accuracy of event dates and complete and accurate information.	

Losing trader response to switch request and event dates - standard switch			
Non-compliance	Description		
Audit Ref: 4.2	TODD		
With: 3 and 4 Schedule 11.3	13 ANs had the AD (advanced metering) response code applied when the AMI flag was set to N.		
	Potential impact: None		
	Actual impact: None		
From: 01-Mar-21	Audit history: Once		
To: 27-Oct-21	Controls: Strong		
	Breach risk rating: 1		
Audit risk rating	Rationale	for audit risk rati	ng
Low	The controls have improved to strong with implementation of new AMI hierarchy logic on 27/10/21 to ensure that the AD code is only applied where the AMI flag is set to Y. The audit risk rating is low as metering information is also available to the gaining trader directly from the registry.		
Actions taken to resolve the issue		Completion date	Remedial action status
TODD Response: Non-Compliance accepted.		October 2021	Cleared
13 ICPs had response code AD (advanced metering) invalidly applied. None of the ICPs had the AMI flag selected at the time of the switch • As this was a technical breach, no action was taken to correct the AN information provided			
Further development was undertaken, and improved logic implemented to resolve the system hierarchy logic that was applying the incorrect code			

Preventative actions taken to ensure no further issues will occur	Completion date
TODD:	October 2021
New hierarchy AN logic was deployed to ensure that AD is only sent when the AMI flag is set to Y	

Losing trader must provide final information - standard switch

Non compliance) a a a wine ti a m	
Non-compliance	L	Description	
Audit Ref: 4.3	TODD		
With: 5 Schedule 11.3	Up to March 2022 CS average daily consumption is based on the average daily consumption over the previous year, not the last actual read-to-read period. At least ten CS files were confirmed to have incorrect average daily consumption recorded.		
	WISE		
	Incorrect calculation of average daily	consumption.	
	Potential impact: Low		
	Actual impact: Low		
From: 01-Mar-21	Audit history: Multiple times		
To: 31-Mar-22	Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale for audit risk rating		
Low	For TODD, the controls have improved to strong with implementation the new average daily kWh logic in March 2022 which ensures that average daily kWh reflects the daily consumption between the last two actual readings. The audit risk rating is low because the values provided do reflect a reasonable estimate of daily average consumption for the ICPs.		
	For WISE, the controls over CS file generation rated as moderate because most file content is correct. The average daily consumption is not calculated as described in the Registry Functional Specification and the controls over this portion of the process are weak.		
	Overall, I have assessed the controls to be moderate.		
	The audit risk rating is assessed to be low as the average daily consumption values applied in the CS files give a reasonable estimate of the average daily consumption for the ICP.		
Actions taken to resolve the issue		Completion date	Remedial action status
TODD Response:		March 2022	Identified
Non-Compliance accepted			
During the audit period, CS average daily consumption was based on the average daily consumption over the previous year, not the last actual read-to-read period. At least ten CS files were			

confirmed to have incorrect average daily consumption recorded. • Development undertaken by Nova to correct the consumption calculation was implemented on 29 March 2022 WISE Response: Non-Compliance accepted. Incorrect calculation of average daily consumption WISE will change our process to calculate and send average daily consumption based on the last two actual readings at the time of sending the CS file.	Q2 2022	
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD:	March 2022	
Development to change the daily consumption calculation to last actual read-to-read period completed and delivered March 2022.		

Retailers must use same reading - standard switch			
Non-compliance	C	escription	
Audit Ref: 4.4 With: 6(1) and 6A Schedule 11.3 From: 21-Dec-21 To: 21-Dec-21	TODD One RR breach. Potential impact: Low Actual impact: Low Audit history: Multiple times Controls: Strong		
Audit risk rating	Breach risk rating: 1 Rationale	for audit risk rati	ng
Low	The controls over the read renegotiation process are strong. The audit risk rating is low. The volume of late RR files was small.		
Actions taken to resolve the issue		Completion date	Remedial action status
TODD Response: Non-Compliance accepted One inaccurate read type			Identified

 Human error resulted in a read being recorded as estimated instead of actual. No corrective action was taken as there was no material impact to the customer or gaining retailer 	
Preventative actions taken to ensure no further issues will occur	Completion date
TODD: Nova will continue with on-going refresher training, review processes and where possible identify improvement	On-going

Losing trader provides info	Losing trader provides information - switch move			
Non-compliance	0	Description		
Audit Ref: 4.8	WISE			
With: Clause 10(1)	Two E2 breaches.			
Schedule 11.3	Potential impact: None			
	Actual impact: None			
	Audit history: None			
From: 01-Mar-21	Controls: Moderate			
To: 27-Oct-21	Breach risk rating: 2			
Audit risk rating	Rationale	for audit risk rati	ng	
Low	The controls are assessed as moderate due to the manual processes employed and a single operator is responsible for this task meaning there is little opportunity for any independent QA checks prior to submitting the AN file.			
	The audit risk rating is assessed as low.			
Actions taken to resolve the issue		Completion date	Remedial action status	
WISE Response: Non-Compliance accepted.		On-going	Identified	
Two ICPs had event dates prior to the requested date.				
WISE continues to review to implement improvements	-			
Preventative actions tak	cen to ensure no further issues will occur	Completion date		
WISE:		On-going		
WISE will undertake proces	ss review to strengthen controls in esher training			

Losing trader must provide final information - switch move			
Non-compliance	Description		
Audit Ref: 4.10	TODD		
With: 11 Schedule 11.3	Up to March 2022 CS average daily consumption is based on the average daily consumption over the previous year, not the last actual read-to-read period. At least ten CS files were confirmed to have incorrect average daily consumption recorded.		
	The CS files for 0000021298EA958 (21/8/21), 0007156981RNB03 (4/11/21), 0037930087PC48C (29/4/21) and 0478644574LC1E4 (19/6/21) were issued with correct read values but incorrect read types. The opening estimate read on the occupier account was used instead of the closing read on the customer account.		
	The CS files for 0000013595TR992 (17/6/21), 0000160532WAEC6 (3/5/21) and 0000463024WE7FF (13/3/20) contained incorrect last actual read dates because reads after the switch out date were not made misreads.		
	WISE		
	Calculation methodology for average daily consumption not compliant.		
	Potential impact: Low		
From: 01-Mar-21	Actual impact: Low		
To: 31-Mar-22	Audit history: Twice		
	Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale for audit risk rating		
Low	For TODD, the controls are moderate overall:		
	 controls over average daily kWh have improved to strong with implementation the new logic in March 2022 which ensures that average daily kWh reflects the daily consumption between the last two actual readings; the audit risk rating is low because the values provided do reflect a reasonable estimate of daily average consumption for the ICPs, and 		
	 controls are appropriately designed to ensure that correct switch reads and read types are provided, but the process is not always followed correctly, resulting in a small number of incorrect read types and last actual read dates; the audit risk rating is low because all read types are treated as validated or permanent estimates for switching, and the last actual read date can be used to help determine the accuracy of switch event dates but does not have a direct impact on the switching or reconciliation process. 		
	For WISE, the controls over CS file generation rated as moderate because most file content is correct. The average daily consumption is not calculated as described in the Registry Functional Specification and the controls over this portion of the process are weak. The audit risk rating is assessed to be low as the average daily consumption values applied in the CS files give a reasonable estimate of the average daily consumption for the ICP.		

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted. CS average daily consumption was based on the average daily consumption over the previous year, not the last actual read-to-read period. At least ten CS files were confirmed to have incorrect average daily consumption recorded. • Development undertaken by Nova to correct the consumption calculation was implemented on March 2022	Q4 2022	Identified
Four ICPs had CS files issued with incorrect read types. • The current process for vacant sites resulted in inaccurate read types being captured as the opening estimate read was included in the CS files. The recommendation has been accepted with an improved process to be implemented by Q4 2022		
Three ICPs had incorrect last actual read dates provided Actual reads received after the switch out date were not misread prior to the creation of the CS file due to human error. This resulted in the CS file containing last actual read dates that were after the switch effective date.		
WISE Response:	Q2 2022	
Non-Compliance accepted.		
Incorrect calculation of average daily consumption		
WISE will change our process to calculate and send average daily consumption based on the last two actual readings at the time of sending the CS file.		
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD: Development to change the daily consumption calculation to last actual read-to-read period completed and delivered 29 March 2022.	Q4 2022	
Vacant site processes are currently being reviewed with improvements to be implemented by Q4 2022		
Refresher training was delivered in April 2022 to reduce the risk of missing the action to misread actual reads gained post switch effective date prior to CS creation.		
WISE: As above.		

Gaining trader changes to switch meter reading - switch move			
Non-compliance		escription	
Audit Ref: 4.11	TODD		
With: 12 Schedule 11.3	14 RR breaches.		
	The RR request for 0001010055ENDB readings rather than two actual readi		pported by customer photo
From: 17-Aug-21	Potential impact: Low		
To: 15-Dec-21	Actual impact: Low		
	Audit history: Multiple times		
	Controls: Strong		
	Breach risk rating: 1		
Audit risk rating	Rationale	for audit risk rati	ng
Low	The controls over the read renegotiat breaches occurred because of delays issue an RR. Read attainment during 19. One of the ten RRs checked was rontrary to TODD's process. This is lil	in obtaining the t the audit period I not supported by	wo actual reads required to nas been impacted by Covidvalidated actual readings,
	The audit risk rating is low. The late R and revised reconciliation data is was		
Actions tak	en to resolve the issue	Completion date	Remedial action status
TODD Response:			Identified
Non-Compliance accepted			luentineu
	ollowing best practices and only sends neframe when required to correct		
actual reads. • Human error mea followed, and cus	g customer photos reads instead of ant that Nova's processes were not stomer reads were used to calculate a ead of actual reads.		
As there was no financial i this.	mpact Nova choose not to correct		
Preventative actions ta	ken to ensure no further issues will occur	Completion date	
TODD: • The staff member reads is no longer	r who made the error on customer r with Nova.	On-going	

Nova will continue with ongoing refresher training, review		
processes and where possible identify improvement		
opportunities.		

Gaining trader informs registry of switch request - gaining trader switch			
Non-compliance	С	Description	
Audit Ref: 4.12	TODD		
With: 14 Schedule 11.3	ICP 0000008633CPA4B (1/3/21) had a HH NT issued but should have had a MI NT issued because it was a meter category 2 ICP.		
	Potential impact: Low		
	Actual impact: None		
From: 01-Mar-21	Audit history: Twice		
To: 01-Mar-21	Controls: Strong		
10. 01 14101 21	Breach risk rating: 1		
Audit risk rating	Rationale for audit risk rating		
Low	The controls are recorded as strong as processes in place are robust. The audit risk rating is low as only one ICP was affected, and there was no impact on submission.		
Actions taken to resolve the issue		Completion date	Remedial action status
TODD Response: Non-Compliance accepted	ı.		Identified
This was caused by	le type was sent instead of MI by human error not following correct ntified in our pre-switch controls.		
As no impact to the custor send a switch reversal	mer or gaining trader, Nova did not		
Preventative actions ta	ken to ensure no further issues will occur	Completion date	
TODD: Refresher training has been this process.	en delivered to all staff responsible for	April 2022	

Losing trader provision of information - gaining trader switch		
Non-compliance	Description	
Audit Ref: 4.13 With: 15 Schedule 11.3	TODD Five ANs had response code AD (advanced metering) invalidly applied. None of the ICPs had the AMI flag selected at the time of the switch.	

From: 25-Mar-21 To: 17-Jun-21	Potential impact: Low Actual impact: Low Audit history: Twice Controls: Strong
	Breach risk rating: 1
Audit risk rating	Rationale for audit risk rating
Low	The controls are now strong because the system issue resulting in the AD code being applied for HHR meters where the AMI flag was set to N has been resolved, and the issue has not occurred since October 2021. The impact is low, because metering details can be confirmed from other information recorded on the registry.

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted.	October 2021	Cleared
Five ICPs had response code AD (advanced metering) invalidly applied. None of the ICPs had the AMI flag selected at the time of the switch • As this was a technical breach, no action was taken to correct the AN information provided Further development was undertaken to resolve the system		
hierarchy logic that was causing the incorrect code to be used		
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD: New hierarchy AN logic was deployed to ensure that AD is only sent when the AMI flag is set to Y	October 2021	

Withdrawal of switch requests			
Non-compliance	Description		
Audit Ref: 4.15	TODD		
With: 17 and 18 Schedule	Three SR breaches.		
11.3	34 NA breaches.		
	WISE		
	One NA breach.		
	HNET		
	One SR breach.		
	One NA breach.		
	Potential impact: Low		
	Actual impact: Low		

	Audit history: Multiple times
From: 27-May-21	Controls: Strong
To: 29-Nov-21	Breach risk rating: 1
	D
Audit risk rating	Rationale for audit risk rating

assessed to be low as the impact to the	he market is minii	mal.
Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response:		Identified
Non-Compliance accepted.		
3 SR breaches, 34 NA breaches		
 Nova considers it is in the best interest of the customer to correct data to invoice accurately and that we 		
comply with Clause 11.2 of part 11 "to provide		
complete and accurate information".		
Nova recognises this may cause some low impact non-		
compliances		
WISE Response:		
Non-Compliance accepted.		
One NA technical breach		
One NW file was sent past compliance timeframes due		
to identifying an incorrect ICP as being gained for a new customer.		
new customer.		
HNET Response:		
Non-Compliance accepted.		
One SR breach		
 HNET sent the original NW within timeframe. The 		
breach occurred as the losing retailer repeatedly		
rejected the NW, eventually accepting.		
One NA technical breach		
HNET sent the NW to correct the gain date for their customer as		
soon as they were made aware of the move in date changing for		
the customer as a result of COVID=19 restrictions.		
Preventative actions taken to ensure no further issues will	Completion	
occur	date	
TODD, WISE & HNET:	On-going	
Nova will continue with on-going refresher training, review		
processes and where possible identify improvement		
opportunities		

Maintaining shared unmetered load			
Non-compliance	Description		
Audit Ref: 5.1	TODD		
With: 11.14	ICPs 0000020042CP198 and 0000020056CPA3F had their shared unmetered load removed by the distributor effective from 1/12/21. The registry and Orion's unmetered load flag, trader details and daily unmetered kWh have not been updated, and unmetered load submissions are continuing.		
	Potential impact: Low		
From: 01-Dec-21	Actual impact: Low		
To: 21-Apr-22	Audit history: Twice		
	Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale	Rationale for audit risk rating	
Low	Monitoring controls are well designed and identify new unmetered load and unmetered load discrepancies daily, but the exceptions identified are not consistently investigated and resolved promptly due to resourcing. The impact on submission is minor.		
Actions taken to resolve the issue		Completion date	Remedial action status
TODD Response: Non-Compliance accepted.		May 2022	Identified
See Section 3.7 for accepted recommendation on clarifying responsibilities for UML.			
The two ICPs in question have been corrected, with UML updated in both the Registry and Orion.			
Preventative actions to	ken to ensure no further issues will occur	Completion date	
TODD Response: Refresher training will be process knowledge.	delivered in the business to embed	Q3 2022	
This issue has been compounded by resource constraints			

caused by COVID-19. we expect to see a return to our historical

compliance in this area within the coming months.

Electricity conveyed & notification by	embedded generators
--	---------------------

Non-compliance	Description			
Non-compliance Audit Ref: 6.1 With: 10.13 From: 19-Feb-21 To: 20-Jan-22	TODD While meters were bridged, energy was not metered and quantified according to the code for one ICP. 27 ICPs had generation recorded by the distributor and I flow metering where TODD did not record a generation profile and were not corrected until the audit was completed. WISE While meters were bridged, energy was not metered and quantified according to the code for five ICPs. HNET For one ICP 0404307035LC42B an incorrect profile code of PV1 was applied when no generation was present. Potential impact: Low Actual impact: Low Audit history: Multiple times			
	Controls: Moderate			
	Breach risk rating: 2			
Audit risk rating	Rationale for audit risk rating			
Low	Controls are rated as strong for bridged meters, and moderate for distributed generation. Controls are moderate overall because they are not sufficient to ensure that distributed generation profile issues are promptly resolved, or in the case of HNET EG1 profile ICPs, able to be readily resolved. The audit risk rating is low as the volumes for the sample of bridged meters were confirmed to be as accurate as possible. For distributed generation revised data will be provided through the revision process.			
Actions taken to resolve the issue		Completion date	Remedial action status	
TODD Response: Non-Compliance accepted. 27 ICPs did not have a generation profile correctly recorded.		April 2022	Identified	
 Data integrity reporting identified the discrepancies as expected. Due to resource constraints, the corrective actions 				

Non-Compliance accepted.	April 2022	luentineu
27 ICPs did not have a generation profile correctly recorded.		
 Data integrity reporting identified the discrepancies as expected. Due to resource constraints, the corrective actions required following Nova's robust exception identification processes were not always completed during the audit period. 		
One ICP did not have energy correctly metered and quantified while bridged according to the code. • Data integrity reporting identified the discrepancy as expected but the process to resolve this was not followed. • The correction has now been made in Orion and is due		
to be invoiced.		

WISE Response: Non-Compliance accepted. • The existence of bridged meters where energy was not metered or quantified during bridge period is acknowledged HNET Response: Non-Compliance accepted. One ICP had the incorrect profile applied. See section 6.1 • This was due to human error and was corrected in March 2022. Preventative actions taken to ensure no further issues will. Completion

Preventative actions taken to ensure no further issues will occur	Completion date
TODD: Nova expects COVID-19 to have reduced impact moving forward which will result in increased compliance. Additional training will be carried out for the members of the team who manage the data integrity reports on these items to be completed Q3 2022	Q3 2022
WISE: WISE continues to work with MEPs through service level agreements and on-going regular operational meetings to ensure bridging of meters continues to be an undesirable outcome	
HNET: A weekly internal review process has been instigated to review all ICPs with PV1 profile to confirm if an export meter is connected	

Responsibility for metering at GIP			
Non-compliance	Description		
Audit Ref: 6.2	TODD (TGTL)		
With: 5 of Schedule 15.2	The MEP and certification for MKE1101TGTLGG wasnot completed before the previous certification expired.		
	Potential impact: Low		
	Actual impact: Low		
	Audit history: None		
From: 02-Jan-21	Controls: Strong		

To: 31 Dec 2021	Breach risk rating: 1		
Audit risk rating	Rationale for audit risk rating		
Low	At the time of the audit the controls were rated as weak because although a process was in place, the required fields were not populated as expected. Nova has since developed a tracking system which includes all metering points, which will be subject to regular reviews to ensure certification and notification occurs as required. I have recorded the controls as strong at the time of the audit report and the effectiveness of the controls will be checked during the next audit. The audit risk rating is low because the no issues were identified at the time the installation was recertified.		
Actions t	taken to resolve the issue Completion Remedial action status date		

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted.	May 2021	Identified
 Permission restrictions on the Reconciliation Manager's (RM) portal resulted in Accucal not being able to update the certification date for MKE1101TGTLGG. RM provided Accucal with access to make updates on TGTL's behalf at which state the certification dates were updated. 		
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD: The RM has granted Accucal permissions to make updates on behalf of the TGTL code	April 2022	
Todd Generation have implemented a new tracking system for Generation Meters to monitor certification expiry and plan maintenance on these assets. Increased compliance with reduced risk of certification breaches is expected as an outcome.		

Collection of information by certified reconciliation participant		
Non-compliance	Description	
Audit Ref: 6.5	TODD	
With: 2 Schedule 15.2	Four ICPs were not interrogated within their maximum interrogation cycle.	
	Potential impact: None	
From: 14-Jan-19	Actual impact: None	
To: 07-Apr-21	Audit history: None	
	Controls: Strong	
	Breach risk rating: 1	

Audit risk rating	Rationale for audit risk rating	
Low	The controls are recorded as strong because most ICPs were interrogated within their maximum interrogation cycle, and AMS had attempted to resolve the issues preventing interrogation.	
	The impact is low because the ICPs are not expected to be consuming energy.	

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted. Monitoring and investigation occurred on all sites impacted. One site is pending decommission, the remaining three will be resolved when the mains are turned back on.	On-going	Identified
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD: Monthly monitoring of missing data resulting in estimates for C&I TOU ICPs for billing and reconciliation. Site visits are initiated to obtain data / restore comms in instances where a temporary vacancy is not expected.	On-going	

Interrogate meters once		
Non-compliance	Description	
Audit Ref: 6.8	TODD	
With: 7(1) and (2) Schedule 15.2	Exceptional circumstances were not proven for six of the ten ICPs sampled that were not read during the period of supply.	
	Potential impact: Low	
	Actual impact: Low	
	Audit history: Multiple times	
From: 19-May-21	Controls: Weak	
To: 10-Dec-21	Breach risk rating: 3	
Audit risk rating	Rationale for audit risk rating	
Low	Controls are rated as weak for TODD because the read attainment process for NHH non-AMI meters has been suspended since August 2021, making it unlikely that the best endeavours requirements will be met for most ICPs. The impact of the suspension is low, because even if the process was operating it may not be possible to achieve read attainment because of Covid-19 restrictions.	

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted.	June 2022	Identified
Due to the changing COVID alert levels since August 2021, Nova paused the customer communication processes developed to achieve read attainment to support staff, contractor, and public health. • Our processes to increase read attainment will be reinstated from 1 June 2022, following the country entering Orange Alert Level. The process was not immediately reinstated to allow opportunity to attempt internal meters and confirm status of access issues.		
Preventative actions taken to ensure no further issues will	Completion	
occur	date	
The processes described by the auditors will be reinstated from 1 June 2022. Nova expects to see increased read attainment from this point.	June 2022	
Nova's view is prioritizing public safety throughout the COVID 19 response over meter read attainment was the appropriate		
approach,		

NHH meters interrogated annually		
Non-compliance	Description	
Audit Ref: 6.9	TODD	
With: 8(1) and (2) Schedule 15.2	The best endeavours requirements were not met for nine of the ten ICPs sampled that were not read during the previous 12 months.	
	Potential impact: Low	
	Actual impact: Low	
	Audit history: Twice	
From: Jan-21 to Dec-21	Controls: Weak	
	Breach risk rating: 3	
Audit risk rating	Rationale for audit risk rating	
Low	Controls are rated as weak for TODD because the read attainment process for NHH non-AMI meters has been suspended since August 2021, making it unlikely that the best endeavours requirements will be met for most ICPs. The impact of the suspension is low, because even if the process was operating it may not be possible to achieve read attainment because of Covid-19 restrictions.	

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted. See section 6.8	June 2022	Identified
Due to the changing COVID alert levels since August 2021, Nova paused the customer communication processes developed to achieve read attainment to support staff, contractor, and public health. • Our processes to increase read attainment will be reinstated from 1 June 2022, following the country entering Orange Alert Level. The process was not immediately reinstated to allow opportunity to attempt internal meters and confirm status of access issues.		
Preventative actions taken to ensure no further issues will	Completion	
occur	date	
The processes described by the auditors will be reinstated from 1 June 2022. Nova expects to see increased read attainment from this point.	June 2022	
Nova's view is prioritizing public safety throughout the COVID 19 response over meter read attainment was the appropriate approach,		

NHH meters 90% read rate		
Non-compliance	Description	
Audit Ref: 6.10	TODD	
With: 9(1) and (2) Schedule 15.2	The best endeavours requirements were not met for eight of the ten ICPs sampled that were not read during the previous four months.	
	HNET	
From: Sep-21 to Dec-21	Exceptional circumstances not proven for nine NSPs where the four-month read attainment was below 90%.	
	Potential impact: Low	
	Actual impact: Low	
	Audit history: Once	
	Controls: Weak	
	Breach risk rating: 3	
Audit risk rating	Rationale for audit risk rating	
Low	Controls are rated as weak for TODD because the read attainment process for NHH non-AMI meters has been suspended since August 2021, making it unlikely that the best endeavours requirements will be met for most ICPs. The impact of the	

suspension is low, because even if the process was operating it may not be possible
to achieve read attainment because of Covid-19 restrictions.

to achieve read attainment because of Covid-19 restrictions.		
Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted. See section 6.8	June 2022	Identified
 Due to the changing COVID alert levels since August 2021, Nova paused the customer communication processes developed to achieve read attainment to support staff, contractor, and public health. Our processes to increase read attainment will be reinstated from 1 June 2022, following the country entering Orange Alert Level. The process was not immediately reinstated to allow opportunity to attempt internal meters and confirm status of access issues. 		
HNET Response: Non-Compliance accepted.		
HNET accepts that exceptional circumstances were not proven for 9 NSPs. COVID-19 and the resulting public health measures have increased the difficulties in gaining reads.		
Preventative actions taken to ensure no further issues will occur	Completion date	
 Todd: The processes described by the auditors will be reinstated from 1 June 2022. Nova expects to see increased read attainment from this point. Nova's view is prioritizing public safety throughout the COVID 19 response over meter read attainment was the appropriate approach, 	June 2022	
HNET:		
HNET will continue to actively work with external agents to gain actual reads in the earliest timeframe possible		

Correction of HHR metering information		
Non-compliance	Description	
Audit Ref: 8.2	TODD	
With: 19(2) Schedule 15.2	HHR corrections for AMI meter exchanges results in some volume not being accounted for.	
	Potential impact: Low	
	Actual impact: Low	

From Jan-21 to Dec-21	Audit history: None Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale	for audit risk rati	ng
Low	Controls are rated as moderate for TODD because for AMI meter changes the automated process does not handle this scenario well, resulting in some unaccounted for consumption. C&I HHR data corrections have more robust checks in place to ensure all volume is reflected in submission. The risk rating is low as the market impact is assessed as minor to both HHR submissions and also the downstream calculation of seasonal shapes by the Reconciliation Manager.		
Actions tal	en to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted	l.	Q4 2022	Identified

	date	
TODD Response: Non-Compliance accepted.	Q4 2022	Identified
Nova is investigating options to integrate the meter removal read manually taken at the register level with the AMI reads at the data stream level to use both in the half-hour estimation process. • This is complicated by register read indexes being out of step in some cases with the AMI midnight reads delivered by the MEP making the two sets of reads incompatible e.g., ARC meters. • The option of always removing an ICP from HHR submission (changing to RPS) when an AMI-to-AMI meter exchange occurs is being considered as an alternative.		
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD: If an appropriate estimation option cannot be found to account for the partial day, affected ICPs can be backdated to remove them from HHR reconciliation and move them back to RPS prior to the meter exchange.	Q4 2022	

Identification of readings	
Non-compliance	Description
Audit risk rating	Rationale for audit risk rating
Low	The controls over the read renegotiation process are strong, a small number of errors occurred where a step was missed when updating the readings. The audit risk rating is low because there is no impact on the submission process; all switch event readings are treated as validated by the reconciliation process.

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted.	Q4 2022	Identified
 Three inaccurate read types recorded in a RR file. See sections 4.4 and 4.11 Human error resulted in a read being recorded as estimated instead of actual. No corrective action was taken as there was no material impact to the customer or gaining retailer Four ICPs had CS files issued with incorrect read types. See section 4.10 The current process for vacant sites resulted in inaccurate read types being captured as the opening estimate read was included in the CS files. The recommendation has been accepted with an improved process to be implemented by Q4 2022 		
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD: • Vacant site processes are currently being reviewed with improvements to be implemented by Q4 2022 Nova will continue with on-going refresher training, review processes and where possible identify improvement opportunities	Q4 2022	

Meter data used to derive	volume information
Non-compliance	Description
Audit Ref: 9.3 With: 3(5) Schedule 15.2	TODD for AMS and EDMI data collection The EIEP3 and GENDF file formats may round the trading period data to two decimal places if the meter does not have a multiplier and the volume for that hour has a non-zero value in the third decimal place. TODD AMI data AMI readings with decimal places are rounded to zero decimal places on import into Orion, and the rounded readings are used to calculate submission data.
From: 1-Jun-20 To: 14-Apr-22	Potential impact: Low Actual impact: Low Audit history: None Controls: Moderate Breach risk rating: 2

Audit risk rating	Rationale	for audit risk rati	ing
Low		The controls are rated as moderate because they are not sufficient to ensure that submission information is consistently calculated from unrounded data.	
	number of ICPs are expected to be at decimal place under certain circumst	For HHR, the impact is assessed to be low for the EIEP3 format, because a small number of ICPs are expected to be affected and the issue only affects the third decimal place under certain circumstances. There is no impact for the GENDF file format, because AMS completes submission for GENH ICPs.	
	For AMI, the impact is assessed to be expected to be very small, and the obecause there will be under and over	verall differences	are expected to be small
Actions t	aken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepto	ed.	Q3 2022	Investigating
Nova will investigate wit values can be delivered	h AMS/EDMI to confirm If unrounded		
Preventative actions	taken to ensure no further issues will	Completion	

occur

date

Q3 2022

Calculation of ICP days	
Non-compliance	Description
Audit Ref: 11.2	TODD
With: 15.6	Zeroing does not occur for AV110 submissions. At least two HHR ICP days differences between AV110 submissions and the registry were caused by backdated withdrawals or NSP changes where data recorded against the old aggregation attributes combination for the period was not zeroed.
	WISE
	Incorrect ICP days for two ICPs (0351490850LCAAD & 1002056702LCCFC).
	HNET
From: Jan-21	Zeroing does not occur for AV110 submissions. At least two HHR ICP days differences between AV110 submissions and the registry were caused by backdated withdrawals or NSP changes where data recorded against the old aggregation attributes combination for the period was not zeroed.
To: Dec-21	Potential impact: Low
	Actual impact: Low
	Audit history: Once
	Controls: Moderate
	Breach risk rating: 2

TODD:

As above

Audit risk rating	Rationale for audit risk rating
Low	The controls are rated as moderate overall.
	The incorrect ICP days affects only two ICPs.
	 Zeroing processes are in place at NSP level for volume information, but not ICP days.
	The impact is assessed to be low based on the differences identified.

Actions taken to resolve the issue	Completion date	Remedial action status
WISE Response: Non-Compliance accepted.	April 2022	Identified
Two ICPs with Incorrect ICP days Caused by incorrect information updated into PEBS due to processes not being followed in full. PEBS was corrected in audit resolving the issue		
TODD & HNET Response:		
Unable to identify the non-compliance in the AV110 HHR ICP days as the submissions appear to have been provided in accordance with 15.6. The issue with zeroing appears to result from legacy behaviour in the RM's system that is not supported by the Code, rather than because of non-compliant trader submissions.		
Preventative actions taken to ensure no further issues will	Completion	
occur	date	
WISE: Further controls have been put in place preventing the inputting of incorrect information into PEBS	April 2022	
TODD & HNET:		
As above		

Electricity supplied inforr	nation provision to the reconciliation manager
Non-compliance	Description
Audit Ref: 11.3 With: 15.7	HNET Electricity supplied file incorrect for the period April to December 2021. Potential impact: Low Actual impact: Low
From: 01-Apr-21 To: 31-Dec-21	Audit history: Multiple Controls: Moderate Breach risk rating: 2

Audit risk rating	Rationale	for audit risk rati	ing
Low	Controls are rated as moderate, as they are sufficient to mitigate the risk of incorrect as billed data for most ICPs. The impact is rated as low because there is no impact on market submission, and only one ICP was affected.		
Actions ta	ken to resolve the issue	Completion date	Remedial action status
HNET Response: Non-Compliance accepted.		March 2022	Identified
Electricity supplied file incorrect for the period April to December 2021 A process error meant that a compensation factor was applied twice to certain ICPs. A fix in the process was implemented in March 2022			
Billed vs Submission volumes for the last six months have been reviewed and proven compliant			

Completion

date

April 2022

Preventative actions taken to ensure no further issues will

occur

As per the auditor's recommendation, beginning April 2022 GR130 reports are reviewed monthly to confirm whether the relationship between billed and submitted data appears

Non-compliance	Description
Audit Ref: 11.4	TODD
With: 15.8	Alleged breach 2103NOVE1 for late provision of submission information.
WILII. 13.8	Potential impact: None
	Actual impact: None
	Audit history: None
From: 30-Apr-21	Controls: Strong
To: 30-Apr-21	Breach risk rating: 1
Audit risk rating	Rationale for audit risk rating
Low	The controls over accuracy and timeliness of submission data are strong. The issuwas isolated.
	The audit risk rating is low based on the submission being three minutes late.

HNET Response:

reasonable

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-Compliance accepted.	Q2 2022	Identified
The AV-140 HHRAGGR submission has been fixed to aggregate together ICP volumes that appear for the same ICP from both the mass market AMI HHR system (Energy Market) and the C&I HHR system (Stark) e.g., upgrades/downgrades mid-month.		
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD:	Q2 2022	
As above		

Creation of submission information			
Non-compliance	Description		
Audit Ref: 12.2 With: 15.4 From: 30-Apr-21 To: 14-Apr-22	Alleged breach 2103NOVE1 for late provision of submission information. ICP 0000394464MP147's unmetered builder's temporary supply was not recorded in Orion or the registry resulting in under submission of 199.68 kWh. ICP 1099569767CN556's controlled meter was confirmed to be bridged from 11/10/21 until the meter was replaced and certified on 28/1/22. A correction was not processed to capture estimated consumption during the bridged period. ICP 0000177620HB50F's meter was stopped between 28/7/21 and 9/2/22. A correction was not processed to capture estimated consumption during the bridged period resulting in under submission of 3,335.834 kWh. Missing HHR submission data was identified for an AMI meter exchange for ICP 0005238501RN91B because interval data from the removed meter was only provided up to midnight the day prior to the meter change. WISE Alleged breach 2108NOVE1 for late provision of submission information. Inactive consumption was not submitted for one ICP (0000037354HR301 – 4.25 kWh). Potential impact: None Actual impact: None Audit history: None Controls: Strong		
Audit risk rating	Breach risk rating: 1 Rationale for audit risk rating		
Low	The controls over timeliness and accuracy of submission data are strong. The exceptions were caused by incorrect inputs into the process rather than systemic issues.		

The audit risk rating is low based on the volume of under and over submission, and that the late submission was three minutes late.

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response:	On-going	Identified
Non-Compliance accepted.		
See sections 2.1, 3.7, 8.4 and 11.2.		
Stopped meter was exchanged on 09/02/2022 and closing read estimated on 08/04/2022. It is not unusual to obtain usage following the meter exchange to establish an estimate retrospectively. This will be washed up.		
WISE Response:		
Non-Compliance accepted.		
One instance of late provision of submission information WISE identified that due to the sudden announcement of a lockdown due to COVID-19 the deadline for submission information was unlikely to be met. WISE notified the Reconciliation Manager by email as soon as this was identified. One instance of incorrect inactive consumption not being submitted. See section 3.9, This has been corrected and was due to human error.		
Preventative actions taken to ensure no further issues will	Completion	
occur	date	
TODD: As above	On-going	
WISE:		
WISE has amended their submission processes to ensure reports are automatically generated prior to the report submission date and time. Under this amended process, WISE is confident submission information will consistently be delivered on time.		

Accuracy of submission in	formation	
Non-compliance	Description	
Audit Ref: 12.7	TODD	
With: 15.12	Breach relating to late submission of data.	

Refer to individual section	s 2.1, 3.7, 8.2, 11.4		
TODD Response: Non-Compliance accepted.			Identified
		date	
Actions tak	The audit risk rating is low based on the volume of under and over submission. Actions taken to resolve the issue Completion Remedial action statu		Remedial action status
	Reconciliation process.	·	·
	has been accounted for. Late delivery submission files had a m	-	
Low	The controls over accuracy of submiss were caused by incorrect inputs into the automated HHR corrections for A	the process rathe	r than systemic issues
Audit risk rating		for audit risk rati	
	Breach risk rating: 2		
	Controls: Moderate		
31 = 11 12.	Audit history: Twice		
To: 14-Apr-22	Actual impact: Low		
From:28-Jul-21	Potential impact: Low		
	WISE Alleged breach 2108NOVE1 for late provision of submission information. Inactive consumption was not submitted for one ICP (0000037354HR301 – 4.25 kWh).		
	UML volumes for eight out of ten ICPs calculation for January 2022.	s sampled did not	match the manual
	accounted for. UML volumes for two out of ten ICPs applies.	sampled were inc	orrect as the UML no longer
	period resulting in under submission of HHR corrections for AMI meter excha		
	in Orion or the registry resulting in under submission of 199.68 kWh. ICP 0007198101RN234's unmetered builder's temporary supply was not remove when it became permanent, resulting in over submission. ICP 1099569767CN556's controlled meter was confirmed to be bridged from 11/10/21 until the meter was replaced and certified on 28/1/22. A correction w not processed to capture estimated consumption during the bridged period. ICP 0000177620HB50F's meter was stopped between 28/7/21 and 9/2/22. A correction was not processed to capture estimated consumption during the bridged period.		
	Inaccurate submission for ARC Innovations HHR metering. ICP 0000394464MP147's unmetered builder's temporary supply was not recorded in Orion or the registry resulting in under submission of 199 68 kWh		

Stopped meter was exchanged on 09/02/2022 and closing read estimated on 08/04/2022. It is not unusual to obtain usage following the meter exchange to establish an estimate retrospectively. This will be washed up.	Completed	
• The billing team are performing a review of the UML data held	Q3 2022	
WISE Response:		
Non-Compliance accepted.		
One instance of late provision of submission information		
WISE identified that due to the sudden announcement of a		
lockdown due to COVID-19 the deadline for submission		
information was unlikely to be met. WISE notified the		
Reconciliation Manager by email as soon as this was identified.		
Preventative actions taken to ensure no further issues will	Completion date	
occur	uate	
TODD: As above.	On-going	
As above.		
WISE:		
WISE has amended their submission processes to ensure		
reports are automatically generated prior to the report		
submission date and time. Under this amended process, WISE is		
confident submission information will consistently be delivered		
on time.		

Accuracy of submission information

Non-compliance	Description
Audit Ref: 12.11	TODD
With: Clauses 4 and 5 Schedule 15.3	HE Scenarios J & K relating to UML load is not producing expected results as the volumes are being profiled using RPS SASV information.
	WISE
	HE Scenario C (ICP become Inactive then Active again within a month) is not producing expected results resulting in some volumes not being reported.
	Potential impact: Low
From: 01-Mar-21	Actual impact: Low
To: 31-Mar-22	Audit history: Once
	Controls: Strong

	Breach risk rating: 1	
Audit risk rating	Rationale for audit risk rating	
Low	TODD	
	Controls are rated as strong as the process used is consistent for all NHH volumes calculated using actual or virtual meter registers and volume differences are small.	
	WISE	
	Controls are rated as strong as the frequency of the conditions required for this HE scenario to occur are rare. The audit risk rating is low as the overall volume of ICPs affected is low.	

Actions taken to resolve the issue	Completion date	Remedial action status
TODD Response: Non-compliance accepted	Q2 2022	Identified
RPS profiling can be removed for UML load. The UML profile has been used for UML submissions historically and it was found that the RM allocates UML profile submission volumes using the RPS profile intramonth so this has perhaps led to a misunderstanding that submissions should also be profiled using the RPS profile. WISE Response: Non-Compliance accepted. Wise is reviewing the HE calculation process to resolve the issue		
when an ICP becomes active and then inactive within one month so the correct HE value can be reflected in submissions.		
Preventative actions taken to ensure no further issues will occur	Completion date	
TODD: As above	Q2 2022	
WISE:		
As above		

Historical estimate reporting to RM		
Non-compliance	Description	
Audit Ref: 13.3	TODD	
With: 10 of Schedule 15.3	Historic estimate thresholds were not met for R3 and R7 for a small number of months and revisions.	
	HNET	

From: Apr 21 r7, Jun to Aug 21 r3	Historic estimate thresholds were not met for R3 and R7 for a small number of months and revisions. Potential impact: Low Actual impact: Low Audit history: Multiple times Controls: Strong Breach risk rating: 1		
Audit risk rating	Rationale for audit risk rating		
Low	Controls are rated as strong, as they are sufficient to mitigate the risk of not meeting the threshold most of the time. The NSPs where the target wasn't met have a low total number of ICPs.		
	The audit risk rating is low because the overall percentage of HE is high.		

Actions taken to resolve the issue	Completion date	Remedial action status
TODD & HNET Response: Non-Compliance accepted.	On-going	Identified
The threshold was not met for some NSPs for revisions 3 and 7 because small number of ICPs are connected at the NSPs. NSPs with a small number of ICPs are susceptible to HE thresholds if one ICP can't be read i.e., due to access issues which was seriously impacted by Covid-19.		
See sections 6.8, 6.9 and 6.10 on read attainment Preventative actions taken to ensure no further issues will	Completion	
occur	date	
TODD & HNET: Continue focusing on optimising its standard by identifying and monitoring its performance and opportunities for improvement	On-going	