

# **Electricity Industry Participation Code 2010**

## **Register of Generators approved as Industrial Co-generators**

Updated: 17 August 2022

The Authority has approved the following generators as type A or type B industrial co-generators under Schedule 13.4 of the Code:

<b>Number</b>	<b>Generator Name</b>	<b>Co-Generating Unit</b>	<b>Type A or type B</b>	<b>Date Approved</b>	<b>Duration of Approval</b>	<b>Conditions</b>
1	Carter Holt Harvey Pulp and Paper Ltd	Kinleith Mill Turbine Generator	B	16 October 2015	Ongoing	<ul style="list-style-type: none"> <li>▪ <u>Grid Emergency</u>. The co-generator must comply with dispatch instructions where the system operator has issued a formal notice as defined in Part 1 of the Code.</li> </ul>
2	Todd Energy Ltd and Whareroa Power Ltd Unincorporated Joint Venture	All 5 units at the Whareroa Co-generator	B	9 September 2019	Ongoing	<ul style="list-style-type: none"> <li>▪ <u>Compliance with Part 8</u>: Continues to comply with voltage Part 8 Code obligations; and</li> <li>▪ <u>Load and generation agreements</u>: Continues to adhere with load and generation agreements for system security during outages; and</li> <li>▪ <u>Grid Emergency</u>: Complies with all dispatch instructions from the system operation under emergency conditions or to alleviate a system constraint</li> </ul>
3	Norske Skog Tasman Ltd	All 4 units at the Kawerau site	A	14 October 2013	Ongoing	<p>Norskse Skog Tasman must comply with dispatch instructions if:</p> <ul style="list-style-type: none"> <li>▪ the system operator has issued a formal grid emergency or warning notice applicable to the area supplied by grid exit points in the Kawerau area; or</li> <li>▪ a constraint situation, which is directly impacted by the Norske Skog industrial co-generating station, exists within the area supplied by grid exit points in the Kawerau area.</li> </ul>
4	Kapuni Energy Joint Venture	All 4 generation units	A	2 March 2020	Ongoing	<ul style="list-style-type: none"> <li>▪ <u>Compliance with Code clause 13.86(c)</u></li> <li>▪ <u>Compliance with Part 8</u>: Continues to comply with voltage Part 8 Code obligations; and</li> <li>▪ <u>Load and generation agreements</u>: Continues to adhere with load and generation agreements for system security during outages; and</li> <li>▪ <u>Grid Emergency</u>: Complies with all dispatch instructions from the system operation under emergency conditions or to alleviate a system constraint</li> </ul>
5	Alinta ENZ Limited	Kilns Cogen Plant, Glenbrook Power Station	B	3 November 2020	Ongoing	<ul style="list-style-type: none"> <li>▪ <u>continues to comply with voltage and frequency Part 8 Code obligations; and</u></li> <li>▪ <u>continues to adhere with load and generation agreements for</u></li> </ul>

						<p><u>system security during outages; and</u></p> <ul style="list-style-type: none"><li>▪ <u>complies with all dispatch instructions from the system operation under emergency conditions or to alleviate a system constraint; and</u></li><li>▪ <u>ensures its offers are of a suitable quality and accuracy to enable the system operator to prepare its schedules in accordance with its obligations under the Code.</u></li></ul>
--	--	--	--	--	--	---