

# 'No regrets' power system studies relating to frequency

Common Quality Technical Group

10 August 2023

# Purpose of 'no regrets' power system studies

## Study 1

- Lower 30 MW threshold for generating stations to be excluded by default from complying with frequency-related AOPs

## Study 2

- Set permitted deadband beyond which generating station must contribute to frequency keeping
- Procure more frequency keeping to manage frequency within normal band (49.8–50.2 Hz)

## Study 3

- Set permitted deadband beyond which generating station must contribute to instantaneous reserve
- Procure more instantaneous reserve to keep frequency above 48 Hz for contingent events and above 47 Hz (North Island) and 45 Hz (South Island) for extended contingent events

# CQTG Frequency Subgroup

## feedback

- < 30 MW generation plant with a frequency controller should be able to enable the frequency controller at relatively low cost
- Some fuel types (solar, wind, geothermal) cannot provide under-frequency reserve
- Consider secondary risk
- Consider how much Net Free Reserve (NFR), or free-riding reserve, exists at present
- Suggestion to analyse the Asset Capability Statements of < 30 MW generators to see the extent to which they could be compliant with the > 30 MW requirements
- Study the benefits of additional frequency reserve provided by lowering the 30 MW threshold
- Discussion on deadband, frequency band and normal band
- Study the effects of widening the frequency keeping band with different deadbands, assuming that the normal band is maintained as 49.8 Hz – 50.2 Hz

## Requirements in other jurisdictions


Synchronous areas	Threshold (MW)	Deadband	Droop
Brazil	30 MW (wind = 10 MW)	+/-40 mHz	2-8%
Great Britain	> 100 MW	+/- 15 mHz	3-5%
Finland	> 10 MW	+/- 10 mHz	2-12%
Italy	> 10 MW	+/- 10 mHz Hydro +/- 20 mHz GT and CC	2-5% Hydro 5-8% Thermal
Ireland	> 2 MW	+/- 15 mHz (Sync Gen) +/- 15 mHz (Wind)	3-5% (Sync Gen) 2-10% (Wind)
New Zealand	> 30 MW	Not specified	0-7%
Singapore	> 10 MW	+/- 50 mHz	3-5%
Spain	All units	+/- 10 mHz	1.5% output @ 0.2Hz deviation
Switzerland	All units	+/- 0-500mHz	2-12%

Source: System operator

# Statistical study

## Present

- 7,656 MW is the total installed capacity of generating units with a capacity of 30 MW or more
- 1,784 MW is the total installed capacity of generating units with a capacity of less than 30 MW
- 101 generating units have a capacity of 30 MW or more
- 214 generating units have a capacity of less than 30 MW
- Almost all generating units with capacity less than 30 MVA are synchronous generators



# Engineering studies – Study 1

Study cases for years 2023 & 2035

Create study scenarios – baseline + others

Create dynamic models & contingencies

## Frequency support study

Consider 30 MW threshold

50% of new generators below the threshold to trip

Check & compare minimum frequency with baseline case

Repeat study with different threshold

## Frequency regulation study


Consider 30 MW threshold

Set new generators below the threshold to have MW control

Check & compare minimum frequency with baseline case





Repeat study with different threshold

# Clarification of the terms used for Study 2




**Frequency keeping band** is the offers in MW by the frequency keeping plant to increase and decrease generation in response to short-term supply and demand imbalances.

# Engineering studies – Study





# Engineering studies – Study 3



**ELECTRICITY  
AUTHORITY**  
TE MANA HIKO



**NGĀ MIHI**