

Draft amendment to clause 5 of Schedule 15.2 of the Electricity Industry Participation Code

The proposed amendments to the Code in relation to clause 5 of Schedule 15.2 are displayed as follows:

- 1) red underlined text or formatting is additional text in the decision compared to the consultation version
- 2) ~~red strikethrough text~~ is text in the decision that is being deleted compared to the consultation version

Schedule 15.2 cl 15.5 Collection of volume information

...

5 Non half hour metering information

(1) A **reconciliation participant** must, when manually **interrogating a non half-hour metering installation**, if the relevant parts of the **metering installation** are visible and it is safe to do so,—

- (a) obtain the **meter** register value; and
- (b) ensure seals are present and intact; and
- (c) check for phase failure if the **meter** supports it; and
- (d) check for signs of tampering or damage; and
- (e) check for electrically unsafe situations, where “electrically unsafe” has the meaning given to it in the Electricity (Safety) Regulations 2010.

(2) Where a reconciliation participant uses a photograph of the meter register supplied by its customer to obtain the raw meter data, the reconciliation participant must:

- (a) take reasonable steps to verify the **meter reading** is accurate; and
- (b) examine the photograph to check for the issues noted in subclauses (1)(b) to (e); and
- (c) keep the photograph and records of the steps taken in subclause (1)(a) and the results of the examination in subclause (1)(b) in accordance with clause 18.